

Square Valve Extension Stems

Telescopic and Non-Telescopic Types

ROUND STEMS
are shown on
page G-2

**TELESCOPIC
EXTENSION STEM**
with gate valve for buried service
(cut-away view shown)



See page F-3 for ordering
information and page F-4
for adjustment ranges

**SQUARE
EXTENSION STEM**
with top nut and
bottom coupling



Traditionally, extension stems have been made from round stock, either pipe or solid round bar. Now, Trumbull's Square Extension Stems can simplify the installation when installers cut extension stems in the field for buried service!

The top and bottom couplings used with Square Extension Stems have an internal square cavity for placement of the square stems. The flat sides inside the cavity bear against the flat sides of the stem, reducing the dependence on the drive pin used to connect both the top and bottom couplings of round extension stems. This enables the installer to cut Square Extension Stems in the field and attach the top coupling with two cap screws, as opposed to drilling for a drive pin. Because of its location, the bottom coupling should be welded or pinned, to provide a secure connection.

When using Trumbull's Valve Position Indicator for buried service, Square Extension Stems are recommended. They eliminate the need to drill holes and pin the stem to attach the Position Indicator and the 2" nut in the field (see pages F-1 and F-2).

Telescopic Extension Stems can also be furnished with Position Indicators for buried service (Patent Pending), as illustrated on pages F-3 and F-4. The Telescopic Extension Stems use a 1-1/4" square tubular upper section which slides inside a 1-1/2" square tubular bottom section. This style has an adjustment range, which saves the installer from field cutting the stem to the exact length required. The adjustment range also provides for ground movement caused by freezing or thawing. The non-telescopic version uses 1-1/4" square stock, either solid or tubular, (as shown on page F-1).

Trumbull can provide Square Extension Stems complete with the required length of square stock, top nut with set screw and welded bottom coupling with two stainless cap screws and jam nuts. Or, the components can be purchased separately for non-telescopic stems (page G-4).

The top nuts and bottom couplings are domestic ductile iron, grade 65-45-12, or Type 316 stainless steel. Carbon or stainless steel bar or tubing is domestic. Telescopic Extension Stems are furnished only as complete units.

See separate literature on Trumbull Floorstands, Floor Boxes,
Stem Guides, Mud Valves and Valve Position Indicators.